



A Brand-new Future of the Sewer System in Taipei



**Department for the Promotion of Private Participation
Ministry of Finance**



**Sewerage Systems Office,
Public Works Department,
Taipei City Government**

Speaker : Chien-Hsien Lee, Director

2020.09.24

Outline

I. Sewer System of Taipei City – Current Situation

II. Sewer System of Taipei City – Planning

III. Sewer System of Taipei City – Vision




I. Sewer System of Taipei City - **Current Situation**

II. Sewer System of Taipei City - Planning

III. Sewer System of Taipei City – Vision



The major targets of sewer system in Taipei



- To ensure a clean and healthy living environment
- To improve and protect the river water quality
- To promote the reuse of water resources



Sewer System of Taipei City

Taipei City (July 2020)

Area : 271 km²

Population : 2,620,037

Household : 1,060,529

Sewer System

- Wastewater treatment plants :

2+1 / 2.06×10^6 CMD

- Pumping stations : 4


- Lifting stations : 36

- Interception facilities :

14 / 676×10^3 CMD


- Gravel treatment facilities :

5 / 64×10^3 CMD




Household Connection Rate

- **890,924 households** having sewerage service and household connection rate is about **84%** (July 2020)



The Amount of Taipei's municipal wastewater (x 10⁴ CMD)





- About 300,000 CMD of excessive sewage is transported to Bali Plant for treatment.

Source: Construction and Planning Agency, Ministry of the Interior
Statistic Table of National Sanitary Sewer Piping Rate and Overall Sewage Treatment Rate(July 2020)

Current Status of Sewerage Pipeline System in Taipei


● Total length of sewerage pipeline 2,717.7 km (2019)

Age (year)	Built year	Length (m)
0~10	2010~2019	656,263
10~20	2000~2009	1,120,651
20~30	1990~1999	472,956
30~40	1980~1989	458,585
>40	Before 1979	24,677
Total		2,717,688



● Age profile of existing sewerage pipelines

Water Quality Trends of Taipei Rivers Over the Last 12 Years





I. Sewer System of Taipei City – Current Situation

II. Sewer System of Taipei City – **Planning**



III. Sewer System of Taipei City – Vision



Climate Change



2020, Japan. Source : Associated Press



2019, India. Source : Reuters



2020, Taiwan. Source : China TV



2016, Paris. Source : Associated Press




2015, California. Source : Tech News



2017, Taiwan . Source : China Times 9

International Trends and Indicators




Ensure availability and sustainable management of water and sanitation for all

Sustainable Development Goals (SDGs)

Percentage of City Population Served by Wastewater Collection

Percentage of the City's Wastewater Receiving Tertiary Treatment



Percentage of City Population Served by Wastewater Collection

Percentage of the City's Wastewater Receiving Primary Treatment

Percentage of the City's Wastewater Receiving Secondary Treatment

Percentage of the City's Wastewater Receiving Tertiary Treatment



New Issues Facing of Sewer System in Taipei

1. Wastewater Treatment

- Build a new generation water resource center
- Increase the production of reclaimed water

4. Household Connection



- Change in contracting method
- Rule amendment
- Adoption of new techniques

2. Emergency Response

- Change the form of manhole covers
- Electronic Early Warning and Emergency Response Platform
- Sewerage System Hydraulic Monitoring Center

3. Lifespan Extension Plan

- Sewage Treatment plant
- Pipeline Inspection & Repairing
- Water Quality Audit





Wastewater Treatment

-Build a New Generation Water Resource Center

Shezidao WRRC

Tertiary treatment
Treatment capacity :
35,000CMD

Total sewage
treatment capacity:
975,000 CMD

(Existing) Neihu STP

Secondary treatment
Treatment capacity :
240,000CMD

(Existing) Dihua STP


Secondary treatment
Treatment capacity :
500,000CMD

Mingsheng WRRC

Tertiary treatment
Treatment capacity :
40,000CMD

Binjiang WRRC

Tertiary treatment
Treatment capacity :
160,000CMD




Wastewater Treatment

-Build a New Generation Water Resource Center



✓ New Generation Water Resource Center

∞ **Circular Economy**



- Methane is recovered for fuel or power generation.
- Dried sludge is manufactured into water permeable paving and flower containers.
- Reclaimed water is reused.

✓ Water quality requirements are far higher than discharge standards

AO+MBR System

Design Discharge Water Quality (mg/L)

BOD	SS	TN	NH ₃ -N
10	4	15	5

Wastewater Treatment

-MingSheng Water Resource Reclaimed Center



● Sewer Intelligent Operation Management Center



● Sewer Environmental Education Center



Wastewater Treatment

-Binjiang Water Resource Reclaimed Center



Light well

Eco gallery

Sunshade

Eco flood retention pond

Rainwater collection

Solar panel

Water permeable paving



Wastewater Treatment

-Build Smart Online Water Intake System for Reclaimed Water





再生水水質即時監測系統

COD	濁度	NH ₃ -N	NO ₃ -N	TDS
1.2	0.3	0.4	7.2	132
●	●	●	●	●
溫度	pH	餘氯	EC	硬度
27.3	7.3	0.7	197	49
●	●	●	●	●


Online Quality Analysis



Monitoring Points



Smart Kiosk



RO System and Pumping Station



Emergency Response - Challenges and Difficulties

Extreme rainfall



Water volume increased drastically in the sewerage system



Air in the pipelines is compressed by the large volume of water and not vented in time



Manhole cover explosion




Source : TVBS




Source : CNA


Emergency Response - Replacing Manhole Cover




Pressure-resistant Manhole Cover



Total Replacement Numbers



Before



After





Emergency Response

- Existing Sewerage System Hydraulic Monitoring Center




Plant Operation Situation

Water Level and Flow Monitoring



Emergency Response

-Early Warning and Emergency Response Platform




Emergency Response

-Early Warning and Emergency Response Platform




□ SWMM model simulation for Dihau WWTP inflow during Storm water event

109/5/28



109/6/14





Emergency Response

-Early Warning and Emergency Response Platform






Emergency Response

-Early Warning and Emergency Response Platform

溢流潛
勢模擬



操作建議

近期建議 起始時間: 2020/08/28 上午 08:31

歷史查詢 結束時間: 2020/09/01 上午 08:31

時間	模式	廠站	建議層級
2020/08/28 14:30:00	避免淹水	連化抽水站	1
2020/08/28 14:50:00	避免淹水	連化抽水站	1
2020/08/28 14:50:00	避免淹水	連化抽水站	1
2020/08/28 15:20:00	避免淹水	連化抽水站	1
2020/08/28 15:20:00	避免淹水	連化抽水站	1
2020/08/28 15:20:00	避免淹水	連化抽水站	1
2020/08/28 15:20:00	避免淹水	連化抽水站	1
2020/08/28 15:20:00	避免淹水	連化抽水站	1
2020/08/28 15:50:00	避免淹水	連化抽水站	1
2020/08/28 15:50:00	避免淹水	連化抽水站	1
2020/08/28 15:50:00	避免淹水	連化抽水站	1
2020/08/28 16:20:00	避免淹水	連化抽水站	1
2020/08/28 16:20:00	避免淹水	連化抽水站	1
2020/08/28 16:20:00	避免淹水	連化抽水站	1

2020/8/28 下午 03:20:00 採用資料 (即時雨量: 6小時, 預測雨量: 18小時)

2: 舒流點啟動抽水站繞流模式, 2020/8/28 20:10抽水至 8 台(流量 93549.2 CMH)無法充分抽水

報警通知

警報列表 過濾警報 清除警報

時間	廠站	警報訊息
2020/09/01 09:57:47	AE30	水位監測站: 二級警戒 水深比: 51% 管徑: 1
2020/09/01 09:57:47	B33	水位監測站: 二級警戒 水深比: 70% 管徑: 3
2020/09/01 09:57:47	B36	水位監測站: 一級警戒 水深比: 89% 管徑: 3.4
2020/09/01 09:57:47	BJ19	水位監測站: 二級警戒 水深比: 54% 管徑: 1.2
2020/09/01 09:57:47	C09	水位監測站: 一級警戒 水深比: 100% 管徑: 1.65
2020/09/01 09:57:47	CA48	水位監測站: 二級警戒 水深比: 59% 管徑: 1.2
2020/09/01 09:57:47	D11	水位監測站: 一級警戒 水深比: 90% 管徑: 2
2020/09/01 09:57:47	1587	水位監測站: 一級警戒 水深比: 100% 管徑: 2
2020/09/01 09:57:47	S1-7-01	水位監測站: 二級警戒 水深比: 67% 管徑: 3
2020/09/01 09:57:47	BA-01	水位監測站: 二級警戒 水深比: 51% 管徑: 0.8
2020/09/01 09:57:47	EA-01	水位監測站: 二級警戒 水深比: 69% 管徑: 0.7
2020/09/01 09:57:47	SHL-01	水位監測站: 一級警戒 水深比: 100% 管徑: 2
2020/09/01 09:57:47	PC-01	水位監測站: 二級警戒 水深比: 78% 管徑: 0.8
2020/09/01 09:57:47	PE-02	水位監測站: 二級警戒 水深比: 63% 管徑: 1
2020/09/01 09:57:47	PB-CH-01	水位監測站: 二級警戒 水深比: 65% 管徑: 1.5
2020/09/01 09:57:47	PA-22	水位監測站: 二級警戒 水深比: 58% 管徑: 0.8
2020/09/01 09:57:47	S1-2-08	水位監測站: 二級警戒 水深比: 65% 管徑: 3.8
2020/09/01 09:57:47	WV-01	水位監測站: 一級警戒 水深比: 100% 管徑: 1.8
2020/09/01 09:57:47	XB-01	水位監測站: 二級警戒 水深比: 52% 管徑: 0.6
2020/09/01 09:57:47	XC-00	水位監測站: 二級警戒 水深比: 50% 管徑: 0.6
2020/09/01 09:57:47	M45	水位監測站: 一級警戒 水深比: 63% 管徑: 1.5



Emergency Response

-Early Warning and Emergency Response Platform

污水抽水站

設備	狀態
進化抽水站	
進流閘門	開
撈污機	12345
抽水機 (CMS: 3.1)	123456789
B43抽水機	1234
濕井液位計(超音波)	-10.49 M
濕井液位計(氣泡式)	1.40 M
南放流閘門	開
南越淡閘門	開
北放流閘門	開
北越淡閘門	開
獅子頭抽水站	
進流閘門	開
撈污機	12345678
抽水機	12345678
省陰井液位計	0.00 M
市陰井液位計	0.00 M
疏流閘門	開
龍形隧道進口閘門	開
龍形隧道出口閘門	開
龍形隧道繞流閘門	開
新莊抽水站	
匯流閘門	開
匯流液位計	未完工
進流閘門	開
撈污機	12
抽水機	1234
濕井液位計	0.00 M
汐止抽水站	
進流閘門	開
撈污機	12
抽水機	12345
濕井液位計	

河川水位站

河川水位站	水位	趨勢	更新時間
南湖大橋	0.07	-	2020/08/14 09:25
臺北橋	0.14	-	2020/08/14 09:25
新海橋	0.4	-	2020/08/14 09:25
秀朗橋	2.02	-	2020/08/14 09:25

污水處理廠

設備	狀態
進化污水處理廠	
進流閘門	開
進流瞬間流量	0.00 CMM
放流抽水機	1234
放流瞬間流量	0.00 CMM
內湖污水處理廠	
1號工作井1800mm閘門	開
1號工作井2800mm閘門	開
廠內G14閘門	開
濕井水位計1	471.86 cm
濕井水位計2	482.73 cm
進流抽水機	12345
紓流抽水機	12
放流抽水機	1234
八里污水處理廠	
撈污機	1234
前處理繞流閘門	開
海放站抽水機	1234
海放站壓差計	0.40 0.27 1.23 0.60
海放站放流流量	0.00 62.10 0.00 0.00

揚水站

揚水站	抽水機狀態	浮球液位
巨蛋	123	低
大道路	12345	
松信	123	低
師大	12	低
忠孝1號	12	
忠孝2號	12	中
懷生	12	
中正	1234567	2
重慶	12	低
天成飯店	123	
天津	12	低
雲國東	12	低
中山北	12	低
大湖國小	12	中

繞紓流設施

設備	狀態
進化緊急進流抽水站	
進流閘門	開
蝶閘	開
抽水機	123
進化緊急紓流抽水站	
進流閘門	開
放流管蝶閘	開
蝶閘	開
抽水機	12
忠孝紓流站	
抽水機	12
士林紓流站	
抽水機	123
松信紓流站	
抽水機	123
新建紓流站	
抽水機	12
木柵紓流站	
抽水機	12
電動閘A(往揚水站)	開
電動閘B(往景美溪)	開

液位監測站

設施	管徑	水深比	趨勢
A59	2.4	48 %	↑
AE30	1	52 %	↑
B33	3	40 %	↑
B36	3.4	66 %	↑
B41	3.6	49 %	↑
BD16	1.35	24 %	↑
BE33	2	17 %	↑
BF36	2	41 %	↑
BG08	1.8	31 %	↑
BH15	1	45 %	↑
BI09	1.35	38 %	↑
BJ19	1.2	54 %	↑
BK40	1.65	47 %	↑
C09	1.65	66 %	↑
CA48	1.2	57 %	↑
CB10	1.2	30 %	↑

雨量觀測站

雨量站	時雨量強度	趨勢	更新時間
北投國小	0 mm	-	2020/08/14 09:25
陽明高中	0 mm	-	2020/08/14 09:25
太平國小	0 mm	-	2020/08/14 09:25
雙園	0 mm	-	2020/08/14 09:25
中和	2 mm	-	2020/08/14 09:25
板橋	0 mm	-	2020/08/14 09:25

礮間處理設施

設施	進流流量(CMD)	放流流量(CMD)	抽水機
南湖	111.20	66.00	12
成美	0.00	0.00	12
忠孝			1234
貴陽	1.40		123
景美	10238.40		123

截流站

截流站	進流閘門	出流閘門
瓦礫截流站	開	
永和截流站	開	
中和截流站	開	
中原截流站	開	
同安截流站	開	
重陽截流站	開	
漢美截流站	開	
藍洲截流站	開	
二重截流井	開	
頂坎截流站	開	
中港截流站	開	
中港截流站	開	
鴨母港截流站	開	
玉成截流站	開	開
南京截流站	開	開
松山截流站	開	開
撫遠截流站	開	開
中山截流站	開	
大龍截流站	開	
新生截流站	開	
建國截流站	開	開
景美截流站	開	

Emergency Response

-Early Warning and Emergency Response Platform




- APP Functions:
1. Real time rainfall
 2. River water level
 3. Pumping stations
 4. Intercetors
 5. Manhole water level
 6. Gate Operation of WWTP





Lifespan Extension Plan - Wastewater Treatment plants

WWTP	Equipment upgrade Duration	Budget (NTD)
Dihua	2018-2022	711,500
Neihu	2018-2021	209,000
Bali	2016-2021	701,000



Lifespan Extension Plan

-Purchase Wastewater Treatment Services and Equipment Upgrades



Procurement Contract

- Purchase long term wastewater treatment service
- ROT concept

Purpose

- Efficiency improving
- Reducing interface conflict

Service Fee

- Base on the amounts of wastewater

Quality Assurance




- Accountability and Strict audit

●Stable

●Reliable

●Responsible

Lifespan Extension Plan - Pipeline Inspection and Repairing





Household Connection Upgrade




Change in
contracting
method

Improve
household
connection
rate

Rule
amendment

Adoption of
new
techniques




32

Household Connection - Rule Amendment




Incentives

● Subsidizing policy adapt



- ✓ Scope expansion
- ✓ Scale increase



Penalties

● Inspection enforcement

- ✓ Announcement of penalties for households not connected to existing sewerage systems with deadlines for improvement.



User-pay

● Water pollution prevention fee

- ✓ Announcement of water pollution levy for households not connected to existing sewerage systems.

I. Sewer System of Taipei City – Current Situation

II. Sewer System of Taipei City – Planning


III. Sewer System of Taipei City – Vision



Visions for Taipei City sewer system

- **2030 – Wastewater Treatment self-sufficiency**
- **2032 – 90% household connection rate**

Wastewater flow
(x 10⁴ CMD)



Sustainable River Water Quality Improvement

(Existing) Bali Plant

Primary Treatment
Suburban sewage transport
through Taipei City:
70,000 ~ 80,000 CMD

(Existing) Neihu Plant

Secondary treatment
Wet season: **< 240,000 CMD**
Dry season: **140,000 ~ 160,000 CMD**

Shezidao Plant

Tertiary treatment
Wet season: **35,000 CMD**
Dry season: **35,000 CMD**

Minsheng Plant


Tertiary treatment
Wet season: **40,000 CMD**
Dry season: **40,000 CMD**

(Existing) Dihua Plant

Secondary treatment
Wet season: \leq **450,000 CMD**
Dry season: **500,000 ~ 550,000 CMD**


Binjiang Plant

Tertiary treatment
Wet season: **160,000 CMD**
Dry season: **110,000 ~ 160,000 CMD**



Reclaimed Water in 2030

Total reclaimed water up to **145,000 CMD**



Shezidao Plant

35,000 CMD

Estimated completion time
is 2028

Binjiang Plant

60,000 CMD

Estimated completion time
is 2025

Dihua Plant

10,000 CMD


Neihu Plant

20,000 CMD

Minsheng Plant

20,000 CMD


Estimated completion time
is 2022



Visions for Taipei City

- Habitable
- Recyclable
- Sustainable





Thank for your
attention



Sewerage Systems Office,
Public Works Department,
Taipei City Government